

ਵੱਲ

ਡੀ.ਏ.ਵੀ ਪਬਲਿਕ ਸਕੂਲ ,
ਕੋਟਕਪੂਰਾ
ਨੰ: DB/7466

ਮਿਤੀ: 26/12/2024

ਵਿਸ਼ਾ: ਸਾਲ 2024-25 ਲਈ ਸਕੂਲ ਬਿਲਡਿੰਗ ਸੇਫਟੀ ਸਰਟੀਫਿਕੇਟ ਜਾਰੀ ਕਰਨ ਬਾਰੇ। (ਡੀ.ਏ.ਵੀ ਪਬਲਿਕ ਸਕੂਲ , ਕੋਟਕਪੂਰਾ- ਸਿੱਖਾਂਵਾਲਾ ਲਿੰਕ ਰੋਡ, ਕੋਟਕਪੂਰਾ)

ਉਪਰੋਕਤ ਵਿਸ਼ੇ ਅਧੀਨ ਸਕੂਲ ਦੀ ਇਮਾਰਤ ਦਾ ਬਿਲਡਿੰਗ ਸੇਫਟੀ ਸਰਟੀਫਿਕੇਟ ਸਾਲ 2024-25 ਲੈਣ ਲਈ ਆਪ ਵੱਲੋਂ ਇਸ ਦਫ਼ਤਰ ਵਿਖੇ ਪ੍ਰਾਪਤ ਹੋਇਆ ਹੈ। ਆਪ ਦੇ ਸਕੂਲ ਦੀ ਬਿਲਡਿੰਗ ਦਾ ਉਪ ਮੰਡਲ ਇੰਜੀਨੀਅਰ ਦੇ ਦਫ਼ਤਰ ਵੱਲੋਂ ਵਿਜ਼ੁਅਲੀ ਇੰਸਪੈਕਸ਼ਨ ਕੀਤੀ ਗਈ ਅਤੇ ਉਨ੍ਹਾਂ ਦੀ ਰਿਪੋਰਟ/ਸਿਫਾਰਿਸ਼ ਅਨੁਸਾਰ ਨਿਮ ਨਲਿਖਤ ਨਿਰੀਖਣਾਂ ਅਤੇ ਸ਼ਰਤਾਂ ਅਧੀਨ ਸਾਲ 2024-25 ਦਾ ਸਕੂਲ ਬਿਲਡਿੰਗ ਸੇਫਟੀ ਮਿਤੀ 31-03-2025 ਤੱਕ ਜਾਰੀ ਕੀਤਾ ਜਾਂਦਾ ਹੈ:-

1. ਸਕੂਲ ਕੋਲ ਕਿਸੇ ਅਣਸੁਖਾਵੀ ਆਪਦਾ ਨਾਲ ਨਜਿੱਠਣ ਲਈ ਯੋਜਨਾ ਹੋਣੀ ਚਾਹੀਦੀ ਹੈ, ਜਿਸ ਵਿੱਚ ਐਮਰਜੈਂਸੀ ਦੌਰਾਨ ਬੱਚਿਆਂ ਨੂੰ ਬਿਲਡਿੰਗ ਵਿੱਚੋਂ ਸੁਰੱਖਿਅਤ ਬਾਹਰ ਕੱਢਣਾ ਅਤੇ ਸਬੰਧਿਤ ਵਿਭਾਗ ਨਾਲ ਤਾਲਮੇਲ ਕਰਨ ਦੀ ਯੋਜਨਾ ਹੋਣੀ ਚਾਹੀਦੀ ਹੈ। ਸਕੂਲ ਨੂੰ ਇਸ ਯੋਜਨਾ ਦੀ ਪ੍ਰਭਾਵਸ਼ੀਲਤਾ ਨੂੰ ਯਕੀਨੀ ਬਣਾਉਣ ਲਈ ਨਿਯਮਿਤ ਤੌਰ ਤੇ ਸਮੀਖਿਆ ਅਤੇ ਅਪਡੇਟ ਕਰਦੇ ਰਹਿਣਾ ਚਾਹੀਦਾ ਹੈ।
2. ਜੇਕਰ ਸਕੂਲ ਵੱਲੋਂ ਇਸ ਇਮਾਰਤ ਵਿੱਚ ਕੋਈ ਵਾਧਾ, ਤਬਦੀਲੀ, ਵਿਸਤਾਰ ਅਤੇ ਸੋਧ ਦੀ ਲੋੜ ਹੈ ਜਾਂ ਕੀਤੇ ਜਾਣੇ ਹਨ ਤਾਂ ਇਸ ਦਫ਼ਤਰ ਨੂੰ ਤਰੱਤ ਜਾਂਚ ਦਾ ਪ੍ਰਬੰਧ ਕੀਤੀ ਜਾਣਾ ਚਾਹੀਦਾ ਹੈ ਅਤੇ ਉਸ ਹਿੱਸੇ ਨੂੰ ਮੁਕੰਮਲ ਕਰਕੇ ਉਸਦਾ ਸੇਫਟੀ ਸਰਟੀਫਿਕੇਟ ਇਸ ਦਫ਼ਤਰ ਪਾਸੇ ਫਿਰ ਤੋਂ ਲਿਆ ਜਾਵੇ।
3. ਜੇਕਰ ਬਿਲਡਿੰਗ ਦੀਆਂ ਕੰਧਾਂ, ਨੀਂਹਾਂ ਅਤੇ ਛੱਤਾਂ ਕੁਦਰਤੀ ਆਫ਼ਤ ਜਾਂ ਕਿਸੇ ਹੋਰ ਕਾਰਨ ਕਰਕੇ ਥੋੜ ਜਾਣ ਤਾਂ ਇਸ ਸੂਰਤ ਵਿੱਚ ਸਕੂਲ ਵੱਲੋਂ ਇਸ ਦਫ਼ਤਰ ਨੂੰ ਤੁਰੰਤ ਬਿਲਡਿੰਗ ਦੀ ਹਾਲਤ ਬਾਰੇ ਸੂਚਿਤ ਕੀਤਾ ਜਾਵੇ ਅਤੇ ਨਿਰੀਖਣ ਕਰਵਾਉਣ ਉਪਰੰਤ ਹੀ ਬਿਲਡਿੰਗ ਨੂੰ ਵਰਤੋਂ ਵਿੱਚ ਲਿਆ ਜਾਵੇ।
4. ਸਬੰਧਿਤ ਵਿਭਾਗ ਤੋਂ ਵੱਖਰੇ ਤੌਰ ਤੇ ਫਾਇਰ ਸੇਫਟੀ ਅਤੇ ਇਲੈਕਟ੍ਰੀਕਲ ਸੇਫਟੀ ਸਰਟੀਫਿਕੇਟ ਪ੍ਰਾਪਤ ਕੀਤਾ ਜਾਵੇ।
5. ਸਕੂਲ ਬਿਲਡਿੰਗ ਦੀ ਸੇਫਟੀ ਨੂੰ ਮੁੱਖ ਰੱਖਦੇ ਹੋਏ ਬਿਲਡਿੰਗ ਦੀ ਰਿਪੋਰਟ ਕਰਵਾਉਣ ਦੀ ਜ਼ਿੰਮੇਵਾਰੀ ਸਕੂਲ ਪ੍ਰਬੰਧਨ ਦੀ ਹੈ। ਇਸ ਰਿਪੋਰਟ ਦੇ ਬਾਵਜੂਦ ਸਕੂਲ ਪ੍ਰਬੰਧਨ ਸਾਰੇ ਪੱਖਾਂ ਤੋਂ ਬਿਲਡਿੰਗ ਦੀ ਸੁਰੱਖਿਆ ਲਈ ਜ਼ਿੰਮੇਵਾਰ ਹੈ।
6. Buildtech ਵੱਲੋਂ ਮਿਤੀ 12.11.2024 ਨੂੰ ਸਟਰੱਕਚਰ ਸੁਰੱਖਿਆ ਸਰਟੀਫਿਕੇਟ ਦਿੱਤਾ ਗਿਆ ਹੈ ਅਤੇ ਉਹਨਾਂ ਦੇ ਸਰਟੀਫਿਕੇਟ ਅਨੁਸਾਰ ਸਕੂਲ ਸੈਸ਼ਨ 2024-25 ਲਈ ਵਰਤੋਂ ਲਈ ਸੁਰੱਖਿਅਤ ਹੈ, ਪਰੰਤੂ ਇਸ ਸਕੂਲ ਦਾ ਨਿਰਮਾਣ ਇਸ ਵਿਭਾਗ ਵੱਲੋਂ ਨਹੀਂ ਕੀਤਾ ਗਿਆ ਹੈ, ਇਸ ਲਈ ਇਸ ਵਿਭਾਗ ਦੁਆਰਾ ਸਕੂਲ ਦੀ ਸਟਰੱਕਚਰ ਸੇਫਟੀ ਖਾਸ ਕਰਕੇ ਭੁਚਾਲ ਦੇ ਦ੍ਰਿਸ਼ਟੀਕੋਣ ਤੋਂ ਯਕੀਨੀ ਨਹੀਂ ਬਣਾਈ ਜਾ ਸਕਦੀ ਹੈ।
7. ਸਕੂਲ ਨੂੰ ਸਟਾਫ ਸੈਬਰਾਂ ਨੂੰ ਉਚਿਤ ਸੁਰੱਖਿਆ ਸਿਖਲਾਈ ਪ੍ਰਦਾਨ ਕਰਨੀ ਚਾਹੀਦੀ ਹੈ, ਜਿਸ ਵਿੱਚ ਐਮਰਜੈਂਸੀ, ਫਸਟ ਏਡ ਅਤੇ ਨਿਕਾਸੀ ਪ੍ਰੋਟੋਕੋਲ ਨੂੰ ਸੰਭਾਲਣ ਦੀਆਂ ਪ੍ਰਕਿਰਿਆਵਾਂ ਵੀ ਸ਼ਾਮਿਲ ਹਨ।
8. ਸਕੂਲ ਦੇ ਕਵਰਡ ਏਰੀਏ ਦੇ ਹਿਸਾਬ ਨਾਲ ਜੀ.ਆਰ. ਨੰਬਰ 14306128 ਮਿਤੀ 25.10.2024 ਰਾਹੀਂ ਦਸ ਹਜ਼ਾਰ ਰੁਪਏ (10,000/) ਬਿਲਡਿੰਗ ਨਿਰੀਖਣ ਫੀਸ ਵੱਜੋਂ ਪ੍ਰਾਪਤ ਕੀਤੇ। ਸਕੂਲ ਦਾ ਫਾਇਰ ਸੇਫਟੀ ਸਰਟੀਫਿਕੇਟ 26.06.2025 ਤੱਕ ਵੈਲਿਡ ਹੈ ਅਤੇ ਸਕੂਲ ਪ੍ਰਬੰਧਨ ਸਮੇਂ ਸੀਮਾਂ ਅੰਦਰ ਫਾਇਰ ਸਰਟੀਫਿਕੇਟ ਰੀਨਿਊ ਕਰਵਾਉਣ ਲਈ ਜ਼ਿੰਮੇਵਾਰ ਹੋਵੇਗਾ।
9. ਇਸ ਪੱਤਰ/ਸਰਟੀਫਿਕੇਟ ਦਾ ਸਕੂਲ ਦੀ ਜਗ੍ਹਾ ਦੀ ਮਲਕੀਅਤ ਨਾਲ ਕੋਈ ਸਬੰਧ ਨਹੀਂ ਹੈ।
10. ਇਸ ਪੱਤਰ/ਸਰਟੀਫਿਕੇਟ ਦਾ ਸਕੂਲ ਦੇ ਪਲਾਟ ਏਰੀਏ ਦਾ ਕੋਈ ਸਬੰਧ ਨਹੀਂ ਹੈ।
11. ਇਸ ਮਨਜ਼ੂਰੀ ਦਾ ਸਫ਼ਿਊਲਡ ਰੋਡ ਐਕਟ ਨਾਲ ਕੋਈ ਸਬੰਧ ਨਹੀਂ ਹੈ।
12. ਇਹ ਰਿਪੋਰਟ ਕਾਨੂੰਨੀ ਉਦੇਸ਼ ਲਈ ਵੈਲਿਡ ਨਹੀਂ ਹੈ।

ਨੱਥੀ/ ਸਰਟੀਫਿਕੇਟ

ਪਿੱਠ ਅੰਕਣ ਨੰ:

ਉਪਰੋਕਤ ਦਾ ਉਤਾਰਾ ਉਪ ਮੰਡਲ ਇੰਜੀਨੀਅਰ, ਉਸਾਰੀ ਉਪ ਮੰਡਲ, ਭ ਤੇ ਮ ਸਾਖਾ, ਕੋਟਕਪੂਰਾ ਨੂੰ ਉਨ੍ਹਾਂ ਦੇ ਪੱਤਰ ਨੰਬਰ 221 ਮਿਤੀ 22.11.2024 ਦੇ ਹਵਾਲੇ ਵਿੱਚ ਸੂਚਨਾ ਪਿਤ ਭੇਜਿਆ ਜਾਂਦਾ ਹੈ।

ਕਾਰਜਕਾਰੀ ਇੰਜੀਨੀਅਰ,
ਪ੍ਰਾਂਤਕ ਮੰਡਲ ਭ ਤੇ ਮ ਸਾਖਾ,
ਫ਼ਰੀਦਕੋਟ।

ਮਿਤੀ:

ਕਾਰਜਕਾਰੀ ਇੰਜੀਨੀਅਰ,
ਪ੍ਰਾਂਤਕ ਮੰਡਲ ਭ ਤੇ ਮ ਸਾਖਾ,
ਫ਼ਰੀਦਕੋਟ।

PROFORMA FOR SAFETY OF SCHOOL BUILDING

PART-1

(To be filled by head of School/Institute)

1. Name of the School **DAV Public School**
2. Location **Sikhen Wala Road, Kothearpura.**
3. Plot Area **4840 Sqd. (1 Acre)**
4. Plinth Area **46733 SA.**
5. Number of Storey **3**
6. Year of Construction of Building **2012, 2016**
7. If the building has been constructed under the supervision of the qualified Engineer, the following details may be given
 - a) Name of the Engineer with qualification
 - b) Address of Engineer
 - c) Set of Structural drawings used in the construction if available
 - d) Name & Address of the architect with qualification
8. Whether the building has been constructed for the purpose of
 - a) School Yes/No
 - b) Residential purpose and converted for use as a School Yes/No
9. Materials used for roofs
 - a) R.C.C Slabs/RBC Slabs Yes/No
 - b) R.S joists & Battons Yes/No
 - c) Wooden joists & Battons Yes/No
10. Materials used for walls
 - a) Mud Mortar Yes/No
 - b) Cement Mortar Yes/No
 - c) Lime mortar Yes/No
11. Flooring
 - a) Congremerate Yes/No
 - b) Terrazzo Yes/No
 - c) Brick Paving Yes/No
12. A detailed drawing indicating dimensions of the rooms,
Along with size and location of doors and window (Attached) Yes/No
13. FOR FIRE SAFETY
 - a) Whether the width of the staircase is Mtr. Yes/No
 - b) Whether Portable fire extinguisher exists Yes/No
 - c) Whether School building is Free from inflammable & toxic material Yes/No
 - d) Whether cooking of food is done at a safe place Yes/No
 - e) Whether any Thatch or combustible material has been used Yes/No
14. Requirement for fire Protection Arrangements under NBC Part IV
(For building height less than 15 meter)
 - a) Whether house real provided Yes/No
 - b) Whether down comer provided Yes/No
 - c) Whether underground ~~water~~ storage tank of capacity Yes/No
50000 Ltr. (If covered area exceeds 1500 sqm)



- d) Whether over head tank of capacity 10000 Ltrs. Exists (in case of house real 20000 Lt. Yes/No
- e) Whether on electric and one diesel pump of 3kg/ Cum pressure of capacity 1620 LPM one electric Pump of capacity 180 LPM exist near underground static tank. *Electrical Pump 5HP installed* Yes/No
- f) Whether a Pump 3 kg/ cum pressure & 450/500 LPM exists near over head tank Yes/No


Signature with Stamp seal
of the School/Institution
Principal
DAV Public School
Kotkapura


PART-II

Building Safety Report

Name of School ... *DAV Public School, Kotkapura*

.....
Junior Engineer. *Sh. Kulvan Kumar* have visited the above mentioned school building on *25/11/24*.....and on visually inspection, it Seems visually safe subject the following observation & conditions.

- a) Parameters to check the stability and safety of building such as Architectural Drawings, Bearing capacity, Foundation detail, Structural Drawings, Technical Specifications, Test Reports of Material used, Quality control Reports and certificate from the Engineer In Charges for construction are not available.
- b) In case any addition or expansion and modification to this building are done, Certificate may be re-obtained after the completion from the undersigned.
- c) In case the building is affected by flood or if there is any settlement walls/foundation or sagging of roofs etc, immediate inspection of the undersigned be arranged to check stability and safety of the Building.
- d) A separate certificate regarding Fire Fighting should be obtained from the competent Authority
- e) A separate certificate regarding Electrical works should be obtained from the competent authority.
- f) The owner of the building/Management is fully responsible regarding safety of the building from all angles in spite of this report.
- g) The covered area of the building is *4673.3*..... Sft.
- h) This report is not valid for legal purpose.
- i) The building visually seems safe to occupy for normal use up to *31-03-25*..... under normal circumstances & conditions.


Sub-Divisional Engineer,
Const. Sub Div. PWD (B&R) Br.
Kotkapura.

