



ਦਫਤਰ ਉਪ ਮੰਡਲ ਇੰਜੀਨੀਅਰ, ਜ/ਸ ਅਤੇ ਸੈਨੀਟੇਸ਼ਨ ਉਪ ਮੰਡਲ  
ਨੰ: 1 ਫਰੀਦਕੋਟ, ਜਿਲਾ ਫਰੀਦਕੋਟ - 151203

email. sdesub1@gmail.com

ਵੱਲ

DAV PUBLIC SCHOOL,  
SIKHAN WALA ROAD. KKP.


ਨੰ: 91

ਮਿਤੀ: 03-02-2025

ਵਿਸ਼ਾ:- ਵਾਟਰ ਅਤੇ ਸੈਨੀਟੇਸ਼ਨ ਸਰਟੀਫਿਕੇਟ ਜਾਰੀ ਕਰਨ ਬਾਰੇ।

ਉਪਰੋਕਤ ਵਿਸ਼ੇ ਸੰਬੰਧੀ ਇਸ ਦਫਤਰ ਵੱਲੋਂ ਆਪ ਦੇ ਸਕੂਲ ਦਾ ਵਾਟਰ ਸੈਂਪਲ  
ਲਿਆ ਗਿਆ (ਰਿਪੋਰਟ ਨਾਲ ਨੱਥੀ ਹੈ) ਜੋ ਕਿ ਸਾਫ ਸੁਥਰਾ ਅਤੇ ਪੀਣ ਯੋਗ ਪਾਇਆ  
ਗਿਆ ਹੈ। ਇਸ ਤੋਂ ਇਲਾਵਾ ਆਪ ਦੇ ਸਕੂਲ ਦਾ ਸੈਨੀਟੇਸ਼ਨ ਵੀ ਚੈਕ ਕੀਤਾ ਗਿਆ ਜੋ ਕਿ  
ਸਾਫ ਸੁਥਰਾ ਅਤੇ ਵਧੀਆ ਪਾਇਆ ਗਿਆ। ਉਕਤ ਦੇ ਅਧਾਰ ਤੇ ਆਪ ਨੂੰ ਇਹ  
ਸਰਟੀਫਿਕੇਟ ਜਾਰੀ ਕੀਤਾ ਜਾਂਦਾ ਹੈ।

ਨੱਥੀ/ਵਾਟਰ ਟੈਸਟਿੰਗ ਰਿਪੋਰਟ ਦੀ ਕਾਪੀ

  
ਉਪ ਮੰਡਲ ਇੰਜੀਨੀਅਰ,  
ਜ/ਸ ਅਤੇ ਸੈਨੀਟੇਸ਼ਨ ਉਪ ਮੰਡਲ ਨੰ:1,  
ਫਰੀਦਕੋਟ। ✓

**DISTRICT WATER TESTING LABORATORY, FARIDKOT**

Department of water supply and sanitation, Ghanaiya Chownk, Opposite Khalsa sr. sec. school, Faridkot  
dwtlfdk@gmail.com

To,

DAV Public School KOTKAPURA ,FDK  
DAV Public School KOTKAPURA ,FDK


No.: DWTL/FDK/2425/00292 Dated : 30/01/2025

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. DAV/KKP/551 Dated: 23/01/2025

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 23/01/2025. It is request to fill the attached feedback form and send it back to District water Testing Laboratory, Faridkot

D/A : Test Report



**Authorized Signatory  
For, District water Testing Laboratory  
Faridkot**

## DISTRICT WATER TESTING LABORATORY, FARIDKOT

Department of water supply and sanitation, Ghanaiya Chownk, Opposite Khalsa sr. sec. school, Faridkot  
dwtfdk@gmail.com



TC-13893

### TEST REPORT

Name & Address of Customer : <b>DAV Public School KOTKAPURA ,FDK</b> <b>DAV Public School KOTKAPURA ,FDK</b>		Customer Reference No.	<b>No : DAV/KKP/551 Dated : 23/01/2025</b>	
		Sample Submitted by	<b>MANJEET SINGH</b>	
		Date of Sample Receipt	<b>23/01/2025</b>	
		Analysis Starting Date	<b>27/01/2025</b>	
		Analysis completion Date	<b>28/01/2025</b>	
Discipline : <b>Chemical Testing</b>		Group: <b>Water</b>		
ULR No.:	<b>TC103942500000054F</b>	Sample Type :	<b>Treated Water</b>	
Test Report No.:	<b>DWTL/FDK/2425/00292</b>	Date of Issue :	<b>30/01/2025</b>	
Registration no.:	<b>DWTL/FDK/REG2425/00868</b>	Condition of Sample :	<b>Sealed</b>	
Collection Point:	<b>Treatment Plant (RO/CWPP/ARP/HH Purifier)</b>	Quantity/Type of Bottle:	<b>1000 ml / Plastic Bottles</b>	
Scheme/Source:	<b>Not Mentioned(Not Mentioned)</b>	Location/Depth :	<b>DAV Public School KOTKAPURA ,FDK / NA</b>	
Village :	<b>Not Mentioned</b>	Habitation :	<b>Not Mentioned</b>	
Block:	<b>Kot Kupura</b>	District :	<b>Faridkot</b>	
Latitude :	<b>Not Mentioned</b>	Longitude:	<b>Not Mentioned</b>	

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	6.90	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	<5	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	110	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	BDL	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	Alkalinity(CaCO3)	28	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	Hardness(CaCO3)	36	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	6.41	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	4.86	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	70	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected)
5. \* Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By

**Mrs. Manju**  
Quality Manager  
Authorized Signatory  
For, District water Testing Laboratory  
Faridkot

**DISTRICT WATER TESTING LABORATORY, FARIDKOT**

Department of water supply and sanitation, Ghanaiya Chowk, Opposite Khalsa sr. sec. school, Faridkot  
dwtlfdk@gmail.com

**Payment Receipt**

Receipt No. : 20763

Date : 23/01/2025

Invoice No. : INV/2425/00307

Invoice Date : 23/01/2025

Received From : DAV Public School KOTKAPURA ,FDK  
DAV Public School KOTKAPURA ,FDK

The Sum of Rupees : One Hundred Thirty Only.

In Cash

Rs. : 130.00

Disclaimer: -Payment made by cheque/online mode are subject to clearance by bank.

For District water Testing Laboratory, Faridkot  
Authorized Signatory